



EDC 4 (5311) P3  
IEC 62599-2: 2010

# DRAFT TANZANIA STANDARD

**(Draft for comments only)**

---

**Alarm systems –  
Part 2: Electromagnetic compatibility – Immunity requirements for  
components of fire and security alarm systems**

**TANZANIA BUREAU OF STANDARDS**

---

## **0 National Foreword**

This draft Tanzania Standard is being prepared by the Alarm and Electronic Security Systems Technical Committee of the Tanzania Bureau of Standards (TBS), under the supervision of the Electrotechnical Divisional Standards Committee (EDC)

This draft Tanzania Standard is an adoption of the International Standard IEC 62599-2:2010 *Alarm systems – Part 2: Electromagnetic compatibility – Immunity requirements for components of fire and security alarm systems*, which has been prepared by the International Electrotechnical Commission (IEC).

### **Terminology and conventions**

Some terminologies and certain conventions are not identical with those used in Tanzania Standards; Attention is drawn especially to the following:

- 1) The comma has been used as a decimal marker for metric dimensions. In Tanzania Standards, it is current practice to use “full point” on the baseline as the decimal marker.
- 2) Where the words “International Standard(s)” appear, referring to this standard they should read “Tanzania Standard(s)”.

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

---

**Alarm systems –  
Part 2: Electromagnetic compatibility – Immunity requirements for  
components of fire and security alarm systems**

**Systemes d'alarme –  
Partie 2: Compatibilité électromagnétique – Exigences relatives à l'immunité des  
composants des systèmes d'alarme de détection d'incendie et de sécurité**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE

CODE PRIX

T

---

ICS 13.320

ISBN 978-2-88910-924-1

## CONTENTS

FOREWORD.....		5
1	Scope .....	7
2	Normative references .....	7
3	Terms, definitions and abbreviations .....	8
	3.1 Terms and definitions .....	8
	3.2 Abbreviations .....	9
4	Application of tests .....	9
5	Conditions during testing .....	9
	5.1 Configuration.....	9
	5.2 Environmental conditions .....	10
	5.3 Operating condition .....	10
6	Functional test.....	10
7	Mains supply voltage variations .....	10
	7.1 Object of the test .....	10
	7.2 Principle .....	10
	7.3 Test procedure .....	11
	7.3.1 General .....	11
	7.3.2 Initial examination .....	11
	7.3.3 State of specimen during conditioning .....	11
	7.3.4 Conditioning .....	11
	7.3.5 Measurements during conditioning .....	11
	7.3.6 Final measurements .....	11
	7.4 Criteria for compliance .....	11
8	Mains supply voltage dips and short interruptions.....	11
	8.1 Object of the test .....	11
	8.2 Principle .....	12
	8.3 Test procedure .....	12
	8.3.1 General .....	12
	8.3.2 Initial examination .....	12
	8.3.3 State of specimen during conditioning .....	12
	8.3.4 Conditioning .....	12
	8.3.5 Measurements during conditioning .....	12
	8.3.6 Final measurements .....	12
	8.4 Criteria for compliance .....	12
9	Electrostatic discharge .....	13
	9.1 Object of the test .....	13
	9.2 Principle .....	13
	9.3 Test procedure .....	13
	9.3.1 General .....	13
	9.3.2 Initial examination .....	13
	9.3.3 State of specimen during conditioning .....	13
	9.3.4 Conditioning .....	13
	9.3.5 Measurements during conditioning .....	14
	9.3.6 Final measurements .....	14
	9.4 Criteria for compliance .....	14
10	Radiated electromagnetic fields .....	14

10.1	Object of the test .....	14
10.2	Principle .....	14
10.3	Test procedure .....	14
10.3.1	General .....	14
10.3.2	Initial examination .....	15
10.3.3	State of specimen during conditioning .....	15
10.3.4	Conditioning .....	15
10.3.5	Measurements during conditioning .....	16
10.3.6	Final measurements .....	16
10.4	Criteria for compliance .....	16
11	Conducted disturbances induced by electromagnetic fields .....	17
11.1	Object of the test .....	17
11.2	Principle .....	17
11.3	Test procedure .....	17
11.3.1	General .....	17
11.3.2	Initial examination .....	18
11.3.3	State of specimen during conditioning .....	18
11.3.4	Conditioning .....	18
11.3.5	Measurements during conditioning .....	18
11.3.6	Final measurements .....	18
11.4	Criteria for compliance .....	19
12	Fast transient bursts .....	19
12.1	Object of the test .....	19
12.2	Principle .....	19
12.3	Test procedure .....	19
12.3.1	General .....	19
12.3.2	Initial examination .....	19
12.3.3	State of specimen during conditioning .....	19
12.3.4	Conditioning .....	19
12.3.5	Measurements during conditioning .....	20
12.3.6	Final measurements .....	20
12.4	Criteria for compliance .....	20
13	Slow high energy voltage surge .....	20
13.1	Object of the test .....	20
13.2	Principle .....	20
13.3	Test procedure .....	21
13.3.1	General .....	21
13.3.2	Initial examination .....	22
13.3.3	State of specimen during conditioning .....	22
13.3.4	Conditioning .....	22
13.3.5	Measurements during conditioning .....	23
13.3.6	Final measurements .....	23
13.4	Criteria for compliance .....	23
	Figure 1 – Example of relative orientations of the EUT and the field vectors .....	15
	Figure 2 – Forms of the modulation types relative to the continuous wave .....	16
	Figure 3 – Typical arrangement for coupling onto screened signal lines .....	22

Table 1 .....	11
Table 2 .....	12
Table 3 .....	13
Table 4 .....	16
Table 5 .....	18
Table 6 .....	20
Table 7 .....	22

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**ALARM SYSTEMS –****Part 2: Electromagnetic compatibility – Immunity requirements for components of fire and security alarm systems**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62599-2 has been prepared by IEC technical committee 79: Alarm and electronic security systems.

This standard is based on EN 50130-4 (1995) and its amendments 1 (1998) and 2 (2003), and integrates the most recent ACEC recommendations <sup>1</sup>.

---

<sup>1</sup> ACEC: Advisory Committee on Electromagnetic Compatibility is an IEC committee.

The text of this standard is based on the following documents:

FDIS	Report on voting
79/277/FDIS	79/293/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62599 series, under the general title *Alarm systems*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.



## ALARM SYSTEMS –

### Part 2: Electromagnetic compatibility – Immunity requirements for components of fire and security alarm systems

#### 1 Scope

This part of IEC 62599 for immunity requirements applies to the components of the following alarm systems, intended for use in and around buildings in residential, commercial, light industrial and industrial environments:

- access control systems, for security applications;
- alarm transmission systems<sup>2</sup>;
- CCTV systems, for security applications;
- fire detection and fire alarm systems;
- intruder and hold-up alarm systems;
- social alarm systems.

The tests and severities that should be used are the same for indoor and outdoor applications of fixed, movable and portable equipment.

The levels do not cover extreme cases, which may occur in any location, but with an extremely low probability of occurrence, or in special locations close to powerful emitters (e.g. radar transmitters).

Equipment within the scope of this standard should be designed in order to operate satisfactorily in the environmental electromagnetic conditions of residential, commercial, light industrial and industrial environments. This implies particularly that it should be able to operate correctly within the conditions fixed by the electromagnetic compatibility levels for the various disturbances on the low voltage public supply system as defined by IEC 61000-2-2. The immunity tests in this standard only concern the most critical disturbance phenomena.

For equipment using radio signalling, mains signalling or with connections to the public telephone system, additional requirements, from other standards specific to these signalling media, may apply.

This standard does not specify basic safety requirements, such as protection against electrical shocks, unsafe operation, insulation coordination and related dielectric tests.

This standard does not cover EMC emission requirements. These are covered by other appropriate standards.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

---

<sup>2</sup> Apart from equipment which is part of a public telecommunication network.

IEC 60068-1:1988, *Environmental testing – Part 1: General and guidance*  
Amendment 1 (1992)

IEC 61000-2-2:2002, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4:2004, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:2008, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-11:2004, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

ETSI EN 301 489 (all parts), *Electromagnetic compatibility and radio spectrum matters (ERM) – Electromagnetic compatibility (EMC) standard for radio equipment and services*

ETSI EN 300 339, *Electromagnetic compatibility and radio spectrum matters (ERM) – General Electromagnetic compatibility (EMC) for radio communications equipment*

### **3 Terms, definitions and abbreviations**

For the purposes of this document, the following terms, definitions and abbreviations apply.

#### **3.1 Terms and definitions**

##### **3.1.1**

##### **regional product performance standard**

regional standard which specifies the product performance requirements

NOTE Such a standard may include EMC requirements but is not limited to EMC requirements. (e.g. series for fire alarm systems, series for intruder alarm systems).

##### **3.1.2**

##### **basic EMC standard**

standards giving the description of, and test and measurement methods for an EMC phenomenon, along with details of the test apparatus and test set-up

NOTE Although a basic EMC standard may give guidance on the choice of severity, it does not give the prescribed limits or criteria for compliance.

##### **3.1.3**

##### **intruder alarm system**

alarm system to detect and indicate the presence, entry or attempted entry of an intruder into supervised premises