



DRAFT TANZANIA STANDARD

MEDC13 (5515) P1/ ISO 6182-3:2012 Fire protection — Automatic sprinkler systems - Part 3: Requirements and test methods for dry pipe valves.

TANZANIA BUREAU OF STANDARDS

1 Scope

This part of ISO 6182 specifies performance, requirements, methods of test and marking requirements, for dry pipe valves and manufacturer's specified relevant trim used in dry pipe automatic fire protection systems.

Performance and test requirements for other auxiliary components or attachments to dry pipe valves are not covered by this part of ISO 6182. Quick opening devices, including accelerators, used with dry pipe valves are covered in 6182-4..