



DRAFT TANZANIA STANDARD

MEDC13(5660) P3/ ISO 6182-8:2006 Fire protection — Automatic sprinkler systems — Part 8: Requirements and test methods for pre-action dry alarm valves

TANZANIA BUREAU OF STANDARDS

DRAFT TANZANIA STANDARD

1 Scope

This part of ISO 6182 specifies performance requirements, methods of test and marking requirements for pre-action dry alarm valves and manufacturers' specified relevant trim used in non-interlock pre-action automatic fire protection systems. (See 3.24 for the principle modes of operation of pre-action dry alarm valves.)

Performance and test requirements for other auxiliary components or attachments to pre-action dry valves are not covered by this part of ISO 6182..