



EDC 3 (5) CD3

IEC 61386-22: 2002

DRAFT TANZANIA STANDARD

(Draft for comments only)

Conduit systems for cable management –Part 22: Particular requirements–Pliable Conduit Systems

TANZANIA BUREAU OF STANDARDS

0 National Foreword

This draft Tanzania Standard is being prepared by the Electrical Installations Technical Committee, under the supervision of the Electrical Engineering Divisional Standards Committee (EEDC)

This draft Tanzania Standard is an adoption of the International Standard IEC 61386-22:2002 *Conduits systems for cable management –Part 22: Particular Requirements-Pliable conduit systems*, which has been prepared by the International Electrotechnical Commission (IEC).

Terminology and conventions

Some terminologies and certain conventions are not identical with those used in Tanzania Standards; Attention is drawn especially to the following:

- 1) The comma has been used as a decimal marker for metric dimensions. In Tanzania Standards, it is current practice to use “full point” on the baseline as the decimal marker.
- 2) Where the words “International Standard(s)” appear, referring to this standard they should read “Tanzania Standard(s)”.

Scope

This draft Tanzania standard specifies requirements and tests for conduit systems, including conduits and conduit fittings, for the protection and management of insulated conductors and/or cables in electrical installations or in communication systems up to 1 000 V a.c. and/or 1 500 V d.c. This part specifies the requirements for pliable conduit systems including self-recovering conduit systems.

Draft for Stakeholders Comments Only