



DRAFT TANZANIA STANDARD

Fire extinguishing media - Powder

TANZANIA BUREAU OF STANDARDS

National foreword

The Tanzania Bureau of Standards is the statutory National standards body for Tanzania, established under the Act.No.3 of 1975, amended by Act.No.2 of 2009.

This Draft Tanzania Standard is being adopted by Industrial and laboratory chemicals Technical Committee under the supervision of the Chemicals Divisional Standards Committee.

This Draft Tanzania Standard is the identical adoption of an International Standard, ISO 7202:2018 *Fire extinguishing media - Powder*

The Draft Tanzania Standards shall include the following;

- To include dates of manufacture and expiry as mandatory requirement in marking.
- In clause 8 of the Standard, ISO 7202:2018, the unit “m” to be replaced with “µm”.

Terminology and conventions

Some terminologies and certain conventions are not identical with those used as Tanzania standards; attention is drawn especially to the following: -

The comma has been used as a decimal marker for metric dimensions. In Tanzania Standards, its current practice to use full point on the baseline as the decimal marker.

Where the words “International Standard(s)” appear, referring to this standard they should read “Tanzania Standard”.

Scope

This document specifies requirements for the chemical and physical properties, and for minimum performance in defined test methods, of fire extinguishing powders suitable for use against fires of classes A, B, C and D. Requirements are also given for the information and data to be declared by the manufacturer.

NOTE The classification of fires is given in ISO 3941.