



DRAFT TANZANIA STANDARD

Hinged or pivoted doors — Determination of the resistance to vertical load

TANZANIA BUREAU OF STANDARDS

This draft Tanzania Standard was published under the authority of the Board of Directors of Tanzania Bureau of Standards on yy-mm-dd.

Tanzania Bureau of Standards (TBS) is the statutory national standards body for Tanzania established under the Standards Act No. 3 of 1975, repealed and replaced by the Standards Act No. 2 of 2009.

The Building and Construction Divisional Standards Committee (BCDC), under whose supervision this Tanzania Standard was prepared, consists of representatives from the following organizations:

- * University of Dar es Salaam, College of Engineering and Technology,
Tanzania Commission for Science and Technology (COSTECH)
Ministry of Works
National Housing Corporation (NHC)
Contractors Registration Board (CRB)
- * Ardhi University (ARU)
National Defense Force, National Service Division (JKT)
National Estates and Designing Consultancy Company Ltd (NEDCO)
- * Architects and Quantity Surveyors Registration Board (AQRB)
Institution of Engineers Tanzania (IET)
National Construction Council (NCC)
Engineers Registration Board (ERB)

The organizations marked with an asterisk (*) in the above list, together with the following were directly represented on the Technical Committee entrusted with the preparation of this draft Tanzania Standard:

Ministry of Finance and Planning
Zanzibar Bureau of Standards (ZBS)
National Development Corporation (NDC)
Tanzania Building Agency (TBA)
Tanganyika Wattle Co. Ltd (TANWAT)
Dar es Salaam Glass Works Ltd

Tanzania Bureau of Standards
P O Box 9524
Dar es Salaam
Tel: +255 (22) 2450206/2450949/2450298
Fax: +255 22 2450298
E-mail: info@tbs.go.tz
Website: www.tbs.go.tz

0 Foreword

The Tanzania Bureau of Standards is the statutory national standards body for Tanzania, established under standards Act No. 3 of 1975, amended by Act No. 2 of 2009.

This draft Tanzania Standard is being prepared by BCDC 15 Doors and Windows technical committee under the supervision of the Building and Construction Divisional Committee (BCDC).

This draft Tanzania Standard is an identical adoption of the 2nd Edition of International Standard ISO 8275:2023 *Hinged or pivoted doors — Determination of the resistance to vertical load* published by International Organization for Standardization.

Terminologies and conventions

The text of the International Standard is hereby recommended for approval without modification.

Some terminologies and certain conventions are not identical with those used as Tanzania Standard; attention is drawn to the following:

The comma (,) has been used as decimal marker (.) for metric dimensions. In Tanzania Standards, its current practice to use a full point on the baseline as decimal marker.

Whenever the words “International Standard” appear, referring to this standard, they should be interpreted as “Tanzania Standard”.

**Hinged or pivoted doors —
Determination of the resistance to
vertical load**

Portes battantes ou pivotantes — Détermination de la résistance à la charge verticale





COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Licensed to TBS AZIZ ABDALAAH MSEM
Order # NUMBER/Downloaded: 2026-01-20
Single-user licence only, copying and networking prohibited.

Contents

	Page
Foreword.....	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 General	1
5 Test apparatus	1
5.1 Test surround.....	1
5.2 Loading equipment.....	1
5.3 Measuring equipment.....	2
6 Test specimens	2
7 Procedure	2
8 Expression of results	2
9 Test report	2
Bibliography	4

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 162, *Doors, windows and curtain walling*.

This second edition cancels and replaces the first edition (ISO 8275:1985), which has been technically revised.

The main changes are as follows:

- vertically pivoted doors have been added to the scope;
- the title has been updated;
- this document has been adapted to the current state of the art using Reference [1];
- the technical content has been precised.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Hinged or pivoted doors — Determination of the resistance to vertical load

1 Scope

This document specifies the method to be used to determine the permanent deformation caused when a vertical load is applied to an open door leaf fixed in its own door frame as part of a door set.

This document applies to all vertically hinged or pivoted doors.

The method can also be used with respect to a door leaf submitted for test in a frame, which the manufacturer considers appropriate to and typical for the intended utilization.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 22496, *Windows and pedestrian doors — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 22496 apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

4 General

Downward forces that can reasonably be expected, such as a child swinging on the handle, should neither damage nor impair the performance of a door.

For manufacturers of door leaves whose products are not sold as part of a known door set, provision is made for claiming conformance with the relevant requirements by the testing of such door leaves in a typical frame. Nevertheless, the fact that a particular door leaf meets with the relevant requirements in this way does not necessarily mean that a door assembly incorporating that door leaf will meet the requirements.

5 Test apparatus

5.1 Test surround

The surround in which the test specimen is tested, which shall be sufficiently rigid to withstand the test load without deflecting to an extent likely to influence the test result.

5.2 Loading equipment

A suitable device with weights or a controlled and calibrated ram, accurate to 2 %.

DRAFT STANDARD